



**NOTES**

1. USE CONDUIT HUBS CERTIFIED / APPROVED AS TYPE 4X.
2. NON METALLIC ENCLOSURE DOES NOT PROVIDE GROUNDING BETWEEN CONDUIT CONNECTIONS. USE GROUNDING TYPE BUSHINGS AND JUMPER WIRES.

1 CHANGE WIRE TIES AND TERMINAL BLOCK N/P PER ECN 2002-0109		RPC	SN	APR 02/02
0 FOR RELEASE		RPC	AKG	JULY 24/00
DIMENSIONS ARE IN INCHES		Rev.	Revision / ECN Description	Drawn
		Product Group	ULTRASONICS	Tolerance Unless Otherwise Noted: UOS
<p><b>CONFIDENTIAL</b> <b>IMPORTANT NOTICE</b></p> <p><small>THIS DOCUMENT REMAINS THE PROPERTY OF SIEMENS MILLTRONICS AND IS SUBJECT TO PATENT. IT MAY NOT BE COPIED, AND IS LOANED AND CAN BE UTILIZED ONLY FOR SUCH LIMITED PURPOSES AS MAY BE SPECIFICALLY AUTHORIZED BY SIEMENS MILLTRONICS. IT IS TO BE MAINTAINED CONFIDENTIAL, SINCE IT MAY CONTAIN PROPRIETARY INFORMATION AND TRADE SECRETS OF SIEMENS MILLTRONICS OR OTHERS. THE ITEM DEPICTED MAY ITSELF BE THE SUBJECT OF PATENTS, INDUSTRIAL DESIGN REGISTRATIONS OR COPYRIGHTS OF SIEMENS MILLTRONICS OR OTHERS. THE USE OF THIS DRAWING DOES NOT IMPLY ANY LICENSE UNDER ANY SUCH RIGHTS.</small></p> <p><small>COPYRIGHT SIEMENS MILLTRONICS PROCESS INSTRUMENTS INC. ALL RIGHTS RESERVED</small></p>		Date:	24 JULY 00	Scale:
		Drawn:	R. CLYSDALE	NONE
		Checked:	S. NGUYEN	Size:
		Approved:	A. GHOREISHI	B
		Location:	PETERBOROUGH	TITLE:
				MILLTRONICS ULTRASONIC LEVEL MONITOR C/W HEATER CSA APPLICATIONS
				DRAWING No:
				23650147
				Rev.
				1
		File No.	2365014701	Plot at:
			1=1	Sheet 1 of 1